



## BLOWOFF ASSEMBLY

**NOTES:**

1. POLYETHYLENE ENCASING ON ALL D.I. PIPE.
2. BLOWOFF PIPE SHALL BE SIZED TO PROVIDE A MINIMUM BLOWOFF VELOCITY OF 2 FT/SEC OR PER THE STATE REQUIREMENTS.

REVISIONS
01/16 - MSG EDITS
12/22- MSG EDITS

AMERICAN WATER MILITARY SERVICES GROUP CIVIL BLOWOFF ASSEMBLY DETAIL		
AMERICAN WATER MILITARY SERVICES GROUP CAMDEN, NJ 08102		
AMERICAN WATER M.S.G. 1 WATER STREET CAMDEN, NJ 08102	★	AMERICAN WATER®
DRAWN BY PDK PROJECT ENG'R PDK APPROVED	DATE 06-03-2013 PROJECT N/A	USE DIMENSIONS ONLY SCALE N.T.S.
USE APPROVED DRAWINGS ONLY FOR CONSTRUCTION PURPOSES		MSG-W-15

FINAL

MSG-W-15