



CONNECTION TO EXISTING MANHOLE

NOTES:

1. CORE DRILL NEW PIPE OPENING.
2. INSERT NEW FLEXIBLE CONNECTOR.
3. AFTER INSERTION OF NEW PIPE, MANHOLE SHALL BE VACUUM TESTED IN ACCORDANCE WITH SPECIFICATIONS.

* BRICK MANHOLES CAN NOT BE CORE DRILLED

REVISIONS

MOWAC WASTE WATER STANDARDS CONNECTION TO EXISTING MANHOLE DETAIL

MISSOURI AMERICAN WATER
ST. LOUIS, MO. 63141

MISSOURI AMERICAN WATER ENGINEERING
727 CRAIG ROAD
ST. LOUIS, MO. 63141

DRAWN BY
PROJECT ENG'R
APPROVED

DATE ##-##-2015
PROJECT IP

USE DIMENSIONS ONLY
SCALE N.T.S.



USE APPROVED DRAWINGS ONLY
FOR CONSTRUCTION PURPOSES

MOAWC-WW-12